

WATER METER DEPARTMENT  
 EAST MAIN STREET  
 NEWARK, OHIO

METER DEPT: 349-6775  
 WATER OFFICE: 349-6730

REMOTE REGISTER TO BE 4'-5'  
 ABOVE GROUND ON THE FRONT OR  
 ON THE SIDE NEAR THE FRONT.  
 NOT PERMITTED ON THE REAR.

WIRE ENCASED IN WEATHER-PROOF  
 CONDUIT(WHERE IT IS INACCESSIBLE). \*  
 WIRE TO BE FURNISHED BY THE  
 DIVISION OF WATER. ( NO SPLICING PERMITTED).

STANDARD WALL CLAMPS  
 INSTALLED AT 18" INTERVALS.

\*NOTE: WHEN THE WIRE IS CONSIDERED  
 INACCESSIBLE FOR REPLACEMENT,  
 THE WIRE IS TO BE ENCASED IN  
 WEATHER PROOF CONDUIT.  
 COMPLETE WATER METER/EXTERIOR  
 REGISTER INSTALLATION TO BE  
 INSPECTED AND APPROVED BY THE  
 CITY OF NEWARK, DIVISION OF WATER.

DIMENSIONAL DESIGN FOR  
 METERS AND CONNECTIONS.

| METER    |         | COUPLING (SPUDS)<br>TAILPIECE |        |  |
|----------|---------|-------------------------------|--------|--|
| SIZE     | LENGTH  | LENGTH                        | THREAD |  |
| 5/8x3/4" | 7 1/2"  | 2 1/2"                        | 3/4"   |  |
| F-3/4"   | 9"      | 2 1/2"                        | 3/4"   |  |
| 1"       | 10 3/4" | 2 5/8"                        | 1"     |  |

FOR SIZES 1 1/2" OR LARGER  
 REF. #800-WS-7

